

SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER

Summary Page

PUBLIC WATER SYSTEM NAME: <u>City of Corsicana</u>	PLANT NAME OR NUMBER: <u>Navarro Mills</u>
I certify that I am familiar with the information contained in this report and that, to the best of my knowledge, the information is true, complete, and accurate.	
PWS ID No.: <u>1750002</u> Report for the Month of: <u>August 2006</u>	Operator's Signature: _____ Certificate No. & Grade: <u>WO0004220 A</u> Date: <u>September 1, 2006</u>

TREATMENT PLANT PERFORMANCE			
Total number of turbidity readings:	186	Number of 4-hour periods when plant was off-line:	0
Number of readings above 0.10 NTU:	25	Number of 4-hour periods when plant was on-line but turbidity data was not collected:	0
Number of readings above 0.3 NTU:	0		
Number of readings above 0.5 NTU:	0		
Number of readings above 1.0 NTU:	0		
Maximum allowable turbidity level:	0.3	Number of days with readings above 1.0 NTU:	0 (2)
Percentage of readings above this limit:	0.0 % (1)	Number of days with readings above 5.0 NTU:	0 (3)
Statistical Summary	Maximum turbidity reading:	Average turbidity value:	0.09 NTU
	Minimum turbidity reading:	Standard deviation:	0.016 NTU
Additional report(s) for individual filter monitoring required:		<input type="radio"/> NONE <input type="radio"/> Filter Profile <input type="radio"/> Filter Assessment <input type="radio"/> CPE	
Additional report(s) for individual filter monitoring submitted:		<input checked="" type="radio"/> NONE <input type="radio"/> Filter Profile <input type="radio"/> Filter Assessment <input type="radio"/> CPE	
#NAME?		Number of days when plant was on-line but individual filter turbidity data was not collected: 0	
Number of days with a low CT for no more than 4.0 consecutive hours: 0		Average log inactivation for Giardia: NA	
Number of days with a low CT for more than 4.0 consecutive hours: 0 (4)		Average log inactivation for viruses: NA	
		Number of days when profiling data was not collected: 31	
		Number of days when CT data was not collected: 31	
Minimum disinfectant residual required leaving the plant: 0.5 mg/L		<input type="radio"/> Free Chlorine <input checked="" type="radio"/> Total Chlorine	
Number of days with a low residual for no more than 4.0 consecutive hours: 0			
Number of days with a low residual for more than 4.0 consecutive hours: 0 (5)		Number of days when disinfectant residual leaving the plant was not properly monitored: 0	

DISTRIBUTION SYSTEM			
Minimum disinfectant residual required in distribution system: 0.5 mg/L		<input type="radio"/> Free Chlorine <input checked="" type="radio"/> Total Chlorine	
Total number of readings this month: 56	Percentage of readings with a low residual this month:		0.0 % (6A)
Average disinfectant residual value: 1.88	Percentage of readings with a low residual last month:		0.0 % (6B)
Number of readings with a low residual: 0			
Number of readings with no detectable residual: 0			

PUBLIC NOTIFICATION			
TREATMENT TECHNIQUE VIOLATIONS	YES/NO	If YES, date when notice was given to:	
		COMMISSIONERS	CUSTOMERS*
Were more than 5.0% of the turbidity readings above the acceptable level? - see (1) above	No		
Were there any days with turbidity readings above 1.0 NTU? - see (2) above	No		
Were there any days with turbidity readings above 5.0 NTU? - see (3) above	No		
Were there any periods when the plant failed to meet the CT requirements for more than 4.0 consecutive hours? - see (4) above	No		
Were there any periods when the residuals leaving the plant fell below the acceptable level for more than 4.0 consecutive hours? - see (5) above	No		
Were more than 5.0% of the residuals in the distribution system below the acceptable level for two months in a row? - see (6A) and (6B) above	No		

Due by the end of the next business day.
 * Copies of each Public Notice must accompany this report.

Submit the report by the 10th of the month following the reporting period to:

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY
 WATER SUPPLY DIVISION/PUBLIC DRINKING WATER SECTION (MC-155)
 P.O. BOX 13087, AUSTIN, TEXAS 78711-3087

SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER (cont.)

Turbidity Data Page

PUBLIC WATER SYSTEM NAME: City of Corsicana

PLANT NAME OR NUMBER: Navarro Mills

PWS ID No.: 1750002

Connections: 8,734

Month: August Year: 2006

Population: 24,485

PERFORMANCE DATA																		
Date	Raw Water Pumpage (MGD)	Treated Water Pumpage (MGD)	RAW WATER ANALYSES		SETTLED WATER TURBIDITY (Optional Data)						FINISHED WATER QUALITY							
			NTU	Aik.	Basin No.						Turbidity						Lowest Residual	Time
					1	2	3	4	5	6	NTU1	NTU2	NTU3	NTU4	NTU5	NTU6		
1	9.150	8.025	34	102	1.0	1.2	1.2	1.3	1.2	1.2	0.08	0.08	0.10	0.09	0.09	0.07	2.4	
2	9.110	8.122	35	102	1.0	1.0	1.4	1.2	1.2	1.1	0.08	0.07	0.07	0.09	0.08	0.08	2.5	
3	9.120	7.915	33	103	1.0	1.0	1.2	1.3	1.2	1.2	0.08	0.08	0.08	0.07	0.07	0.06	2.5	
4	9.190	7.867	42	103	1.1	1.0	1.3	1.3	1.2	1.1	0.06	0.06	0.06	0.07	0.06	0.06	2.6	
5	9.570	8.354	36	105	1.3	1.1	1.4	1.3	1.2	1.2	0.09	0.09	0.11	0.11	0.11	0.11	2.7	
6	9.560	7.981	42	102	1.1	1.2	1.4	1.2	1.1	1.2	0.11	0.10	0.08	0.08	0.07	0.07	2.4	
7	8.380	7.269	56	101	1.3	1.2	1.4	1.4	1.3	1.2	0.06	0.07	0.07	0.07	0.07	0.06	2.8	
8	7.210	6.959	47	102	1.2	1.1	1.2	1.3	1.3	1.3	0.07	0.06	0.10	0.09	0.08	0.07	2.5	
9	9.150	7.427	37	100	2.0	1.8	2.7	2.4	2.5	2.5	0.07	0.07	0.09	0.08	0.07	0.07	2.8	
10	8.140	7.381	25	97	1.7	1.5	1.9	2.0	2.0	1.9	0.08	0.08	0.07	0.07	0.06	0.06	2.6	
11	9.520	8.089	40	96	2.0	1.9	2.1	2.0	1.9	2.0	0.08	0.07	0.09	0.08	0.10	0.06	2.8	
12	9.540	7.713	44	98	1.8	1.6	1.9	2.0	1.8	1.6	0.07	0.08	0.08	0.09	0.08	0.08	2.3	
13	8.180	7.789	38	97	1.6	1.6	1.9	1.9	1.7	1.7	0.07	0.07	0.08	0.07	0.08	0.07	2.3	
14	9.040	7.333	34	95	1.6	1.5	2.5	1.9	2.2	1.6	0.07	0.07	0.08	0.09	0.09	0.08	2.4	
15	9.080	7.770	30	92	1.2	1.2	2.4	2.1	1.9	1.9	0.09	0.09	0.08	0.08	0.07	0.08	2.0	
16	9.040	7.288	28	93	1.3	1.1	2.1	1.5	1.5	1.4	0.08	0.08	0.08	0.08	0.09	0.08	2.0	
17	8.810	7.932	33	94	1.1	1.3	1.5	1.4	1.4	1.2	0.08	0.08	0.09	0.10	0.11	0.10	2.4	
18	9.560	7.743	38	95	1.3	1.5	1.4	1.4	1.4	1.4	0.09	0.09	0.09	0.09	0.09	0.07	2.4	
19	7.970	7.477	35	95	1.0	1.2	1.4	1.2	1.2	1.3	0.07	0.09	0.09	0.07	0.09	0.09	2.3	
20	9.180	7.628	28	94	1.1	1.1	1.7	1.6	1.4	1.6	0.11	0.11	0.11	0.09	0.09	0.07	2.6	
21	9.160	7.486	28	95	1.5	1.5	2.6	2.0	2.1	1.8	0.07	0.07	0.07	0.07	0.07	0.08	2.5	
22	7.730	6.656	24	93	1.5	1.6	1.9	1.9	1.7	1.8	0.08	0.08	0.09	0.10	0.08	0.08	2.4	
23	8.070	6.987	22	91	1.1	1.2	1.9	1.5	1.4	1.6	0.08	0.09	0.11	0.11	0.11	0.09	2.5	
24	7.910	6.568	23	93	1.0	1.1	1.3	1.5	1.3	1.3	0.09	0.10	0.09	0.08	0.08	0.07	2.5	
25	9.260	7.817	29	93	1.4	1.2	1.8	1.8	1.8	1.5	0.10	0.13	0.10	0.09	0.10	0.08	2.2	
26	9.250	7.876	31	97	1.3	1.3	1.9	1.8	1.7	1.4	0.08	0.08	0.11	0.11	0.12	0.11	2.7	
27	9.220	7.649	35	98	1.6	1.6	2.1	2.0	2.0	1.8	0.10	0.10	0.09	0.09	0.10	0.10	2.5	
28	7.880	6.362	35	96	1.5	1.4	2.0	1.7	1.7	1.5	0.08	0.09	0.08	0.08	0.10	0.09	1.1	
29	5.940	5.390	27	97	1.1	1.4	1.2	1.3	1.3	1.3	0.10	0.10	0.10	0.15	0.13	0.11	3.2	
30	7.650	5.860	33	95	1.1	0.9	1.7	1.2	1.0	1.1	0.10	0.12	0.13	0.11	0.11	0.12	3.1	
31	7.200	6.218	38	95	0.8	0.8	1.1	1.1	0.8	0.8	0.10	0.09	0.08	0.08	0.08	0.08	2.9	
Total	267.770	228.931																
Avg	8.638	7.385																
Max	9.570	8.354																
Min	5.940	5.390																

NOTE: ONLY use the "Time" column to show the length of time that the disinfectant residual entering the distribution system fell below the acceptable level.

SUBMITTED BY: _____ Certificate No. and Grade: WO0004220 A Date: September 1, 2006

SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER (cont.)
Filter Data Page

PUBLIC WATER
SYSTEM NAME: City of Corsicana
PWS ID No.: 1750002

PLANT NAME
OR NUMBER: Navarro Mills
Month: August Year: 2006

PERFORMANCE DATA																				
INDIVIDUAL FILTER TURBIDITY																				
Date	Filter No. 1		Filter No. 2		Filter No. 3		Filter No. 4		Filter No. 5		Filter No. 6		Filter No. 7		Filter No. 8		Filter No. 9		Filter No. 10	
	Max	4 Hrs	Max	4 Hrs																
1	0.28	X	0.26	X	0.28	X	0.77	0.22	0.25	0.16	0.24	X								
2	0.54	0.12	0.32	0.20	0.27	0.18	0.17	X	0.23	X	0.24	0.22								
3	0.13	X	0.19	X	0.12	X	0.08	X	0.07	X	0.21	X								
4	0.24	X	0.20	X	0.46	0.19	0.28	0.12	0.11	X	0.17	X								
5	0.30	0.13	0.41	0.16	0.22	X	0.18	X	0.62	0.16	0.25	0.22								
6	0.13	X	0.14	X	0.10	X	0.09	X	0.09	X	0.19	X								
7	0.23	X	0.22	X	0.18	0.14	0.26	0.11	0.06	X	0.35	X								
8	0.18	0.11	0.47	0.17	0.19	X	0.16	X	0.16	0.13	0.24	X								
9	0.16	X	0.20	X	0.24	0.14	0.15	X	0.14	X	0.26	0.17								
10	0.20	X	0.37	0.18	0.16	X	0.49	0.18	0.12	X	0.21	X								
11	0.22	0.12	0.18	X	0.15	X	0.18	X	0.09	X	0.22	0.22								
12	0.15	X	0.32	0.19	0.29	0.18	0.16	X	0.52	0.17	0.25	X								
13	0.45	0.16	0.18	X	0.24	X	0.46	0.14	0.19	X	0.29	X								
14	0.20	X	0.16	X	0.21	0.15	0.17	X	0.11	X	0.31	0.29								
15	0.20	X	0.50	0.26	0.19	X	0.19	X	0.60	0.16	0.17	X								
16	0.82	0.14	0.21	X	0.23	X	0.37	0.16	0.17	X	0.25	0.24								
17	0.27	X	0.29	0.19	0.30	0.22	0.20	X	0.25	X	0.26	X								
18	0.24	0.21	0.20	X	0.16	X	0.18	X	0.09	X	0.14	X								
19	0.20	X	0.23	X	0.45	0.19	0.42	0.17	0.20	0.15	0.43	0.27								
20	0.27	0.15	0.53	0.19	0.25	X	0.18	X	0.22	X	0.31	X								
21	0.17	X	0.23	X	0.22	0.18	0.23	X	0.07	X	0.18	X								
22	0.29	X	0.58	0.22	0.31	X	0.45	0.19	0.50	0.20	0.38	0.27								
23	0.92	0.18	0.21	X	0.42	0.21	0.18	X	0.18	X	0.30	X								
24	0.84	X	0.26	0.24	0.21	X	0.84	X	0.35	0.18	0.55	X								
25	0.22	X	0.24	X	0.15	X	0.93	0.14	0.18	X	0.21	X								
26	0.96	0.18	0.88	0.23	0.78	0.21	0.25	X	0.22	X	0.74	0.28								
27	0.55	X	0.23	X	0.41	X	0.61	0.20	0.50	0.16	0.29	X								
28	0.90	X	0.93	X	0.18	X	0.21	X	0.17	X	0.85	X								
29	0.39	0.29	0.35	0.31	0.40	0.29	0.34	X	0.30	X	0.43	0.42								
30	0.26	X	0.27	X	0.24	X	0.47	X	0.31	0.15	0.28	X								
31	0.14	X	0.43	X	0.31	X	0.73	0.18	0.19	X	0.15	X								

SUMMARY & COMPLIANCE ACTIONS	Criteria										Filter No.	Plant
	1	2	3	4	5	6	7	8	9	10		
	Number of days with event(s) above 0.5 NTU at 4.0 hrs this month	0	0	0	0	0	0					
	Number of days with event(s) above 1.0 NTU this month	0	0	0	0	0	0					
	Number of days with event(s) above 1.0 NTU last month	0	0	0	0	0	0					
	Number of days with event(s) above 1.0 NTU two months ago	0	0	0	0	0	0					
	Total number of days with event(s) above 1.0 NTU in three months	#####	#####	#####	#####	#####	#####	#####	#####	#####	#####	
	Number of days with event(s) above 2.0 NTU this month											0
	Number of days with event(s) above 2.0 NTU last month											0
	Does the plant have an approved Corrective Action Plan?	N	N	N	N	N	N					N
Is the plant required to submit a Filter Profile Report?	#####	#####	#####	#####	#####	#####	#####	#####	#####	#####		
Is the plant required to submit a Filter Assessment Report?	#####	#####	#####	#####	#####	#####						
Is the plant required to submit a Request for Compliance CPE?											N	

SUBMITTED BY: _____ Certificate No. and Grade: WO0004220 A Date: September 1, 2006

SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER (cont.)

Disinfection Data Page

PUBLIC WATER SYSTEM NAME: City of Corsicana
PWS ID No.: 1750002

PLANT NAME OR NUMBER: Navarro Mills
Month: August Year: 2006

DISINFECTION PROCESS PARAMETERS							
APPROVED CT STUDY PARAMETERS					PERFORMANCE STANDARDS		
Parameters	Disinfection Zones					Log Inactivations	
	D1	D2	D3	D4	D5	Giardia lamblia Cysts	Viruses
Flow Rate (MGD)	20.250	20.250	20.250			0.5	2.0
T ₁₀ (minutes)	109.1	13.0	100.0				

PERFORMANCE DATA									
Date	DISINFECTION PROCESS DATA								
	Disinfectant	C (mg/L)	Flow (MGD)	Temp (°C)	pH	Giardia Log	Virus Log	Inact. Ratio	Time
1	NA D1								
	FCL D2	3.3	9.200	30.0	7.7				
	FCL D3	3.0	9.200	30.0	7.6				
	D4								
	D5								
2	NA D1								
	FCL D2	3.7	9.200	30.0	7.7				
	FCL D3	3.0	9.200	30.0	7.6				
	D4								
	D5								
3	NA D1								
	FCL D2	3.5	9.100	27.0	7.6				
	FCL D3	3.1	9.100	29.0	7.5				
	D4								
	D5								
4	NA D1								
	FCL D2	4.2	9.400	28.0	7.7				
	FCL D3	2.7	9.400	29.0	7.5				
	D4								
	D5								
5	NA D1								
	FCL D2	3.8	9.600	30.0	7.7				
	FCL D3	2.8	9.600	30.0	7.5				
	D4								
	D5								
6	NA D1								
	FCL D2	3.9	9.700	30.0	7.6				
	FCL D3	2.5	9.700	29.0	7.5				
	D4								
	D5								
7	NA D1								
	FCL D2	4.0	9.500	29.0	7.6				
	FCL D3	3.0	9.500	28.0	7.5				
	D4								
	D5								
8	NA D1								
	FCL D2	4.2	9.300	29.0	7.5				
	FCL D3	3.1	9.300	29.0	7.4				
	D4								
	D5								

PERFORMANCE DATA									
Date	DISINFECTION PROCESS DATA								
	Disinfectant	C (mg/L)	Flow (MGD)	Temp (°C)	pH	Giardia Log	Virus Log	Inact. Ratio	Time
9	NA D1								
	FCL D2	4.3	9.100	28.0	7.6				
	FCL D3	3.2	9.100	28.0	7.4				
	D4								
	D5								
10	NA D1								
	FCL D2	3.6	9.400	28.0	7.6				
	FCL D3	3.2	9.400	29.0	7.5				
	D4								
	D5								
11	NA D1								
	FCL D2	4.1	9.600	29.0	7.6				
	FCL D3	3.1	9.600	28.0	7.5				
	D4								
	D5								
12	NA D1								
	FCL D2	3.8	9.600	29.0	7.6				
	FCL D3	3.0	9.600	29.0	7.5				
	D4								
	D5								
13	NA D1								
	FCL D2	4.5	9.700	30.0	7.6				
	FCL D3	2.5	9.700	31.0	7.5				
	D4								
	D5								
14	NA D1								
	FCL D2	4.3	9.100	31.0	7.6				
	FCL D3	2.7	9.100	29.0	7.6				
	D4								
	D5								
15	NA D1								
	FCL D2	4.2	8.900	29.0	7.7				
	FCL D3	2.0	8.900	30.0	7.5				
	D4								
	D5								
16	NA D1								
	FCL D2	4.6	9.200	29.0	7.7				
	FCL D3	2.1	9.200	30.0	7.5				
	D4								
	D5								

NOTE: ONLY use the "Time" column to show the length of time that the total inactivation ratio was less than 1.00.

SUBMITTED BY: _____ Certificate No. and Grade: WO0004220 A Date: September 1, 2006

