

SURFACE WATER MONTHLY OPERATING REPORT

FOR PUBLIC WATER SYSTEMS THAT ARE USING SURFACE WATER SOURCES
OR GROUND WATER SOURCES UNDER THE INFLUENCE OF SURFACE WATER (cont.)
Turbidity Data Page

PUBLIC WATER SYSTEM NAME: City of Corsicana PLANT NAME OR NUMBER: Lake Halbert
PWS ID No.: 1750002 Plant ID No.: 15000 Connections: 10,905
Month: December Year: 2019 Population: 23,770

PERFORMANCE DATA																			
Date	Raw Water Pumpage (MGD)	Treated Water Pumpage (MGD)	RAW WATER ANALYSES		SETTLED WATER TURBIDITY (Optional Data)						FINISHED WATER QUALITY								
			NTU	Alk.	Basin No.						Combined Filter Effluent Turbidity						Lowest Residual	Time=	
					1	2	3	4	5	6	NTU1	NTU2	NTU3	NTU4	NTU5	NTU6			
1	1.516	1.300	5	102								0.08	0.07	0.05	0.03	0.03	0.03	3.0	
2	0.000	0.000	X	X	X	X						X	X	X	X	X	X	X	
3	0.906	0.810	5	98								x	x	x	0.04	0.06	0.04	2.6	
4	2.390	1.930	5	100								0.04	0.04	0.07	0.05	0.05	0.05	3.0	
5	0.683	0.500	7	108								x	x	x	x	0.06	0.05	2.7	
6	1.580	1.280	6	104								0.04	0.04	0.05	0.04	0.05	0.06	3.2	
7	1.600	1.310	6	104								0.04	0.06	0.06	0.04	0.04	0.04	3.1	
8	1.600	1.310	6	104								0.03	0.04	0.04	0.04	0.03	0.03	3.0	
9	1.620	1.270	5	104								0.03	0.03	0.03	0.03	0.03	0.03	2.9	
10	1.600	1.400	4	102								0.03	0.03	0.03	0.05	0.06	0.04	3.0	
11	1.220	1.120	5	104								0.03	0.03	0.03	0.03	0.03	0.04	3.0	
12	1.220	0.970	5	104								0.04	0.04	0.03	0.03	0.03	0.02	3.0	
13	1.160	1.050	4	102								0.02	0.02	0.04	0.03	0.03	0.03	3.0	
14	0.000	0.000	X	X	X	X						X	X	X	X	X	X	X	
15	1.534	1.220	22	103								x	x	x	0.05	0.03	0.04	2.6	
16	2.875	2.450	8	104								0.03	0.05	0.04	0.04	0.03	0.03	2.9	
17	1.600	1.430	6	104								0.02	0.02	0.03	0.05	0.03	0.04	3.1	
18	1.580	1.410	4	106								0.03	0.03	0.03	0.03	0.03	0.03	2.9	
19	2.345	1.960	4	106								0.03	0.03	0.03	0.04	0.05	0.04	2.8	
20	1.461	1.220	5	108								0.04	0.03	0.03	x	x	x	2.9	
21	1.020	0.760	6	108								x	x	x	0.07	0.06	0.03	2.6	
22	1.990	1.660	5	106								0.03	0.03	0.05	0.03	0.03	0.03	3.1	
23	1.996	1.720	5	106								0.03	0.03	0.04	0.03	0.05	0.06	2.8	
24	1.906	1.670	4	106								0.03	0.04	0.04	0.04	0.04	0.03	2.8	
25	0.000	0.000	X	X	X	X						X	X	X	X	X	X	X	
26	0.472	0.360	4	108								x	x	x	x	x	0.05	2.6	
27	1.620	1.320	4	108								0.04	0.06	0.05	0.06	0.05	0.05	2.8	
28	1.620	1.260	4	110								0.03	0.04	0.03	0.06	0.03	0.04	3.1	
29	1.590	1.480	4	108								0.08	0.02	0.03	0.03	0.03	0.03	2.9	
30	1.332	1.140	3	108								0.02	0.03	0.05	x	0.07	0.04	2.7	
31	1.590	1.340	14	98								0.03	0.03	0.04	0.05	0.04	0.03	3.0	
Total	43.626	36.650		Max	ND	ND						NOTE: ONLY use the "Time" column to show the length of time that the disinfectant residual entering the distribution system fell below the acceptable level.							
Avg	1.407	1.182		Avg	ND	ND													
Max	2.875	2.450		95th %	ND	ND													
Min	0.000	0.000		Min	ND	ND													
95th percentile based on data from all basins										ND									

SUBMITTED BY: _____ Certificate No. and Grade: WO0029648, A Date: January 9, 2020